



N°	TIPO	CAÑO	COND.	TIERRA	TMAG.	ALIMENTA
1	LUZ	11/4	1mm2	2mm2	10A	8 LAMP. 4W LED L2
2	T/C	3/4	2mm2	2mm2	16A	T/C ESTANCO HIPROL.
3	T/C	3/4	1mm2	2mm2	10A	T/C ESTANCO EMERG.
4	LUZ	5/8	2mm2	2mm2	10A	LUCES EXTERIOR L4
5	LUZ	5/8	2mm2	2mm2	10A	LUCES EXTERIOR L4
6	LUZ	5/8	2mm2	2mm2	10A	10 LAMP. LED 6W C/U L
7					10A	RESERVA
8					16A	RESERVA

O1	GRAL. 3P 32 A 6KA 898 230V DESCARGADORES
O2	GRAL.DE TABLERO 3P 32 A 6KA 898 230V
D1	DIFERNCIAL 4P 40 AMP. 30mA FIJO AC/DC

JABALINA TIPO COOPERWELD 2 MTS. 5/8" UNIT - IRAM UBICADA EN LA CAMARA MAS PROXIMA A TABLEROS DE 40X40 CM CON TAPA PESADA EL TOMA CABLE SERA DE BRONCE CON TORNILLO INOXIDABLE C/EXAGONA PARA LA PROTECCION DE LINEAS Ø 50 PVC UNIT 3.2 + CAPUCHON

OBRA:	LOCALIDAD:	FECHA:
ESCUELA AGRARIA FLORIDA	FLORIDA	2019
CALLE: ITUZAINGÓ S/N ESQ.TREINTA Y TRÉS	DEPARTAMENTO:	ESCALA:
	FLORIDA	1:75

ARQUITECTO: \_\_\_\_\_ FIRMA: \_\_\_\_\_

AYTE. de ARQTO.:  
ARQ. GUILLERMO SANCHEZ

TECNICO:	FIRMA:
TEC.ELECT. JULIO CESAR DIAZ	

DIBUJANTE:	
------------	--

AMINA No:

L 23

IE4